

## 2021 PFAS6 RESULTS SUMMARY TABLES

### PFAS6 Results for Forge Village Water Treatment Plant

PFAS6 Results for Forge Village Water Treatment Plant				
Quarterly Compliance Period	Monitoring Period	PFAS6 Result (ng/L)	*Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 1, 2021	January	--	--	20
	February	--		
	March	--		
Quarter 2, 2021	April	12.7	15	20
	May	13.5		
	June	19.5		
Quarter 3, 2021	July	20.6	10	20
	August	6.3		
	September	3.4		
Quarter 4, 2021	October	2.9	6.6	20
	November	3.3		
	December	7.1		
* Quarterly averages are calculated by adding the three-monthly sample results from within the quarter and dividing by three. If any sample result would cause the quarterly average to exceed the MCL, the PFAS6 MCL has been violated.				
All results are in ng/L (ppt).				

### PFAS6 Results for Nutting Road Water Treatment Plant

PFAS6 Results for Nutting Road Water Treatment Plant				
Quarterly Compliance Period	Monitoring Period	PFAS6 Result (ng/L)	*Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 1, 2021	January	--	--	20
	February	--		
	March	--		
Quarter 2, 2021	April	14.2	16	20
	May	17.4		
	June	16.1		
Quarter 3, 2021	July	17.8	17	20
	August	17.2		
	September	16.0		
Quarter 4, 2021	October	16.8	16.4	20
	November	15.4		
	December	17.1		
* Quarterly averages are calculated by adding the three-monthly sample results from within the quarter and dividing by three. If any sample result would cause the quarterly average to exceed the MCL, the PFAS6 MCL has been violated.				
All results are in ng/L (ppt).				